



SARNIA REFINERY

LADDER SAFETY BARS, CHAINS AND SWING GATES

Issue Date: June 16, 2017

Revision #: 2

STANDARD

Document Number:

4000-ZSD-SMSAFESA-00190

Next Review Date: March 16, 2020

Document Owner: Manager, EH&S

Document Contact: Safety Advisor

SCOPE AND PURPOSE:

This Standard defines Sarnia Refinery's requirements for safe use of ladder safety bars, chains and swing gates. This standard replaces S.O. #2.002.

ROLES AND RESPONSIBILITIES:

Employees and Contractors are accountable to this Standard and to follow operating procedures and work practices.

Refinery Leaders are accountable to ensure compliance to this Standard

Refinery Vice President is accountable to approve, maintain and ensure compliance to this standard.

EXCEPTIONS:

There will be no exception to this Standard without the written permission of the Director, Refinery Operations. Approval will be considered only after completion of a formal risk assessment. Our Management of Change process will be employed to document mitigating actions, assign accountabilities and track the abnormal condition. The Management of Change document must be reviewed and approved by the Director, Refinery Operations before permission is granted.

RISK CONTROLS:

At the top of all permanent ladders to platforms on vessels/towers, etc. 1.8 meters or higher there should be a swing gate, safety bar, or safety chain. The purpose of these devices is to prevent a fall when an employee is working on the platform.

All workers shall ensure that these fall protection devices are in the "CLOSED" position when they are working on a platform.

LADDER SAFETY BARS, CHAINS & SWING GATES

Current versions of approved documents are maintained in Livelink. Printed copies are uncontrolled.

Swing gates and safety bars are designed to return to the closed position after a person goes through them onto or off a platform. These devices should never be jammed in the open position and if not closing properly, should be lubricated or repaired so they will close.

END OF STANDARD

<u>REVISION LOG</u>				
Date <small>(MM/DD/YYYY)</small>	Revision	Section	Comments	Editor <small>(Name)</small>
03/19/2010	Original		Transferred into "Standard" template. Revision #Original. Replaces S.O. #2.002	
04/13/2012	1	Risk Controls	Changed height requirement for safety bar, safety chain or swing gate from 3 to 1.8 meters to align with new Fall Protection Standard effective 4/1/12.	
06/25/2012	2	All	Updated format, but content was NOT altered.	
07/24/2013	-	Header	Document Owner & Contact Updated, but NO content changed.	L. Lebert
04/21/2014	-	Title Log	Corrected title. Updated Log template. Content not altered.	
06/16/2017	3	Title	Corrected contact from Loss Advisor to Safety Advisor. Content not altered	T. Richard

LADDER SAFETY BARS, CHAINS & SWING GATES

Current versions of approved documents are maintained in Livelink. Printed copies are uncontrolled.



The following individuals have approved and signed this document.

UserName: Todd Murray (toddmurray)

Title: Mgr EH&S Sarnia Refinery

Date: Wednesday, 05 July 2017, 06:41 AM Mountain Time

Meaning:

=====